

RECEIVED  
NRC

*Southern California Edison Company*

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

1982 MAY -3 PM 1:20

SCE

REGION V

TELEPHONE  
(714) 492-7700

H. B. RAY

STATION MANAGER

April 28, 1982

U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596-5368



Attention: Mr. R. H. Engelken, Regional Administrator

Docket No. 50-361  
Licensee Event Report 82-011  
San Onofre, Unit 2

Dear Sir:

This letter describes a Technical Specification reportable occurrence involving inoperable Engineered Safety Feature Actuation System (ESFAS) instrumentation at San Onofre Unit 2.

Technical Specification 3.3.2.b and Action 13 to Table 3.3-3 requires the Control Room Emergency Air Cleanup System to be maintained in the emergency mode of operation within one hour of the time that both channels of the Control Room Airborne Radiation Monitor are made or discovered to be inoperable. On March 13, 1982, the single operable channel of the monitor was taken out of service for preventive maintenance. Operation of the air cleanup system in the emergency mode was not maintained for the full three hours in which the monitor was out of service; however, both trains of the air cleanup system were operable in the event that manual initiation was required.

Discovery of the reporting omission was made during an internal review of recent operating incidents. This incident was discussed with the Unit 2 Resident Inspector on April 27, 1982, immediately following the evaluation of the event reporting status.

Preparation of a written report and Unit 2 Licensee Event Report 82-011 is being expedited.

Sincerely,

IE22  
5/0

8205100207 820428  
PDR ADOCK 05000361  
S PDR

cc: U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement

U. S. Nuclear Regulatory Commission  
Office of Management Information and Program Control (MPIC)

Institute of Nuclear Power Operations (INPO)

A. E. Chaffee - (USNRC Resident Inspector - San Onofre, Unit 2)