



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 • CLEVELAND, OHIO 44101 • TELEPHONE (216) 622-9800 • ILLUMINATING BLDG. • 55 PUBLIC SQUARE

Serving The Best Location in the Nation

Dalwyn R. Davidson

VICE PRESIDENT
SYSTEM ENGINEERING AND CONSTRUCTION

April 23, 1982



Mr. James G. Keppler
Director, Region III
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

RE: Perry Nuclear Power Plant, Docket Nos.
50-440, 50-441; Unit II Polar Crane
Girder Weld Deficiencies
(RDC 39(81))

REF: Final Report dated February 26, 1982
to Mr. James G. Keppler

Dear Mr. Keppler:

This letter serves to correct our Final Report of the Unit II Polar Crane girder weld deficiencies. Subject Final Report is dated February 26, 1982.

In the portion of the report entitled "Corrective Action Taken to Date", we described the following action to be taken:

"... Once the repair weld is completed, it will be visually inspected and MT examined in accordance with approved procedures"

This statement is incorrect.

Nonconformance Report No. 17-136 which identified the weld deficiencies was dispositioned to include a visual inspection and an ultrasonic examination (UT). The Final Report inadvertently specified a visual inspection with an MT examination. It is the intent of The Cleveland Electric Illuminating Company to perform a UT examination as specified in Nonconformance No. 17-136.

This matter was discussed with Mr. E. H. Nightingale of your office during his inspection conducted at the Perry Nuclear Power Plant on April 22 and 23, 1982.

8205110255 820423
PDR ADOCK 05000440
S PDR

IE27
6/10
IE19
APR 29 1982

Mr. James G. Keppler


-2-

April 23, 1982

The above information supplements our Final Report on this matter.

If you have any questions, please call.

Sincerely,



Dalwyn R. Davidson
Vice President
System Engineering and Construction

DRD/llp

cc: Mr. M. L. Gildner
NRC Site Office

Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

U. S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, D. C. 20555