



Wisconsin Electric POWER COMPANY

231 W. MICHIGAN, P.O. BOX 2046, MILWAUKEE, WI 53201

April 30, 1982

CERTIFIED MAIL

Mr. H. R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. NUCLEAR REGULATORY COMMISSION
Washington, D. C. 20555

Attention: Mr. R. A. Clark, Chief
Operating Reactors, Branch 3

Gentlemen:



DOCKET NOS. 50-266 AND 50-301
TECHNICAL SPECIFICATION CHANGE REQUEST NO. 78
CONTAINMENT COOLING CAPABILITY
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

In accordance with the provisions of 10 CFR Part 50.59, Wisconsin Electric Power Company (Licensee) hereby submits an application for amendments to Facility Operating Licenses DPR-24 and DPR-27 for the Point Beach Nuclear Plant, Units 1 and 2, respectively. The purpose of the amendments is to incorporate certain changes into the Technical Specifications concerning the operability of the containment fan cooling system. These changes were requested by the Nuclear Regulatory Commission in Mr. R. A. Clark's letter dated February 10, 1982.

The proposed Technical Specification revisions, which are provided on the attached Technical Specification pages and identified with margin bars, are discussed as follows:

1. Specification 15.3.3.B, items 1.c and 2.a, have been rewritten as suggested on page 3 of the February 10 letter.
2. Specification 15.4.5.c has been revised to include a monthly containment fan cooler accident fan operability test as requested on page 4 of the February 10 letter. This accident fan operability test is in addition to the various service water valve and flow tests which have been and shall continue to be performed in accordance with our ASME Section XI inservice testing program and the refueling interval backdraft damper and service water bypass valve tests already in the Technical Specifications.

*Accol
5/1/1
w/ check
\$1,600*

8205110502 820430
PDR ADOCK 05000266
P PDR

Mr. H. R. Denton


-2-

April 30, 1982

In accordance with the schedule of amendment fees for reactor facility licenses contained in 10 CFR Part 170.22, Licensee has determined this license amendment approval for Point Beach, Unit 1, to be a Class II amendment. This classification is based on Licensee's determination that the proposed revisions to the Technical Specification are primarily administrative in nature and have no safety or environmental significance. The amendment application for Point Beach, Unit 2, is a duplicate of the Unit 1 request and is therefore classified as a Class I amendment. A check in the amount of \$1,600 for the full approval fees for both classes of amendments is enclosed.

As further specified in the Commission's regulations, we have enclosed herewith three signed originals and, under separate cover, 40 copies of this license amendment application. Please notify us if this application is not completely responsive to your February 10 letter request.

Very truly yours,



Assistant Vice President

C. W. Fay

Enclosures (Check No. 671441)

Copy to NRC Resident Inspector

Subscribed and sworn to before me
this 30th day of April 1982.


Notary Public, State of Wisconsin

My Commission expires July 1, 1984.