

50.55(e) Report

ARIZONA



PUBLIC SERVICE COMPANY

P. O. BOX 21666 · PHOENIX, ARIZONA 85036

April 27, 1982

ANPP-20818-GHD/BSK

U. S. Nuclear Regulatory Commission
Region V
Creskide Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. T. W. Bishop, Chief
Reactor Construction and
Engineering Support Branch

Subject: Time Extension for Report - DER 81-52
A 50.55(e) Potentially Reportable Deficiency Relating
to Unit 1 Low Pressure Safety Injection Pumps and
Containment Spray Pumps Have Potentially Loose Anti-
Rotation Pins
File: 82-019-026
D.4.33.2

Reference: (A) Telephone Conversation between J. Eckhardt and
G. Duckworth on December 30, 1981
(B) ANPP-20014, dated January 28, 1982 (Interim Report)
(C) ANPP-20486, dated March 19, 1982 (Extension)

Dear Sir:

The NRC was notified of a potentially reportable deficiency in Reference (A). An Interim Report was transmitted by Reference (B), and a time extension was requested by Reference (C). At that time, it was estimated that a Final Report would be available by April 30, 1982.

Due to the extensive investigation and evaluation required, it is now expected that this information will be finalized by May 28, 1982, when a complete report will be submitted.

There is no new information or change to the Interim Report at this time.

Very truly yours,

E. E. Van Brunt

E. E. Van Brunt, Jr.
APS Vice President
Nuclear Projects
ANPP Project Director

8205110628 820427
PDR ADOCK 05000528
S PDR

EEVBJr/GHD:skc

cc: See Attached Page 2



RECEIVED
MAY 10 1982
PH 1:23

1E27
S 1/0
82-111

U. S. Nuclear Regulatory Commission
Attention: Mr. T. W. Bishop, Chief
ANPP-20818-GHD/BSK
April 27, 1982
Page 2

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

J. A. Roedel
D. B. Fasnacht
G. C. Andognini
A. C. Rogers
B. S. Kaplan
W. E. Ide
J. Vorees
J. A. Brand
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
R. M. Grant
D. R. Hawkinson
L. E. Vorderbrueggen

R. L. Greenfield
Assistant Attorney General
Bataan Memorial Building
Santa Fe, New Mexico 87503

Ms. Patricia Lee Hourihan
6413 South 26th Street
Phoenix, Arizona 85040