



Public Service Company of Colorado

P. O. Box 361, Platteville, CO 80651

*Category 4
#2*

June 3, 1976
Fort St. Vrain
Unit No. 1
P-76120

Mr. Bob Clark, Chief
Special Reactors Branch
Division of Project Management
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Docket #50-267

Dear Mr. Clark:

Subject: Environmental Qualification
of Safe Shut Down
Equipment and Instrumentation

This is to confirm the telephone conversation of June 3, concerning environmental qualification of instrumentation and equipment necessary to facilitate safe shut down of the facility in the event of a steam line or feedwater line rupture. As indicated in the conversation, certification is in hand for all instrumentation and equipment listed in Table 6.1-1 of our response to question 6.1 contained in amendment 18 to the FSAR. That instrumentation that has been added to the safe shutdown list as the result of our evaluation and assignment of cables as being essential shall be environmentally qualified as rapidly as the qualifications can be obtained. At the time when we exceed 40% power those instruments remaining to be environmentally qualified will be reviewed with I&E and all environmental certifications shall be in hand prior to resuming operation following the first refueling.

Yours very truly,

R. F. Walker
Vice President

RFW:11

B205120136 B20402
PDR FOIA
LYNCH82-149 PDR