



Carolina Power & Light Company

MAY 07 1982



Mr. Darrell G. Eisenhut, Director
Division of Licensing
United States Nuclear Regulatory Commission
Washington, D.C. 20555

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 AND 50-324
LICENSE NOS. DPR-71 AND DPR-62
NUREG-0737 ITEM II.D.3
SAFETY/RELIEF VALVE POSITION INDICATION EQUIPMENT

Dear Mr. Eisenhut:

In a letter dated April 22, 1981, Carolina Power & Light Company (CP&L) revised the schedule for completing the equipment qualification testing for the installed Safety/Relief Valve position indication equipment at the Brunswick Steam Electric Plant. The equipment qualification testing is being conducted for an owners' group of which CP&L is a member. Due to slippage in the owners' group schedule, the qualification testing was not completed by September, 1981, as previously scheduled. The slippage was caused by (1) the owners' group's need to satisfy certain plant-specific concerns of program participants, and (2) anomalies encountered in the post-thermal aging functional tests. The owners' group's current schedule projects completion of the testing by October 1, 1982. Based on this schedule, CP&L will submit the final test report to the NRC by December 1, 1982.

If you require any additional information, please contact our staff.

Yours very truly,

L. W. Eury
Senior Vice President
Power Supply

WRM/lr (n-35)

cc: Mr. J. P. O'Reilly

8205120181 820507
PDR ADOCK 05000324
P PDR

A046
51/0