

OPERATING DATA REPORT

DOCKET NO 50-255
 DATE 5-7-82
 COMPLETED BY DPeterson
 TELEPHONE 616 764-8913

OPERATING STATUS

1. Unit Name: Palisades
 2. Reporting Period: 820401-820430
 3. Licensed Thermal Power (MWt): 2530
 4. Nameplate Rating (Gross MWe): 811.7
 5. Design Electrical Rating (Net MWe): 805
 6. Maximum Dependable Capacity (Gross MWe): *675
 7. Maximum Dependable Capacity (Net MWe): *635
 8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes

9. Power Level To Which Restricted, If Any (Net MWe):
 10. Reasons For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	719	2879	90,854
12. Number Of Hours Reactor Was Critical	0	1223.8	49,947.0
13. Reactor Reserve Shutdown Hours	-	-	-
14. Hours Generator On-Line	0	891.6	47,096.0
15. Unit Reserve Shutdown Hours	-	-	-
16. Gross Thermal Energy Generated (MWH)	0	1,798,560	93,205,824
17. Gross Electrical Energy Generated (MWH)	10**	558,890	28,786,840
18. Net Electrical Energy Generated (MWH)	0	522,105	27,035,038
19. Unit Service Factor	0	31.0	51.8
20. Unit Availability Factor	0	31.0	51.8
21. Unit Capacity Factor (Using MDC Net)	0	28.6	46.9
22. Unit Capacity Factor (Using DER Net)	0	22.5	37.0
23. Unit Forced Outage Rate	100	69.0	34.6
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

25. If Shut Down At End Of Report Period, Estimated Date of Startup: 5-9-82
 26. Units In Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

	Forecast	Achieved
INITIAL CRITICALITY		
INITIAL ELECTRICITY		
COMMERCIAL OPERATION		

*Based on Condenser back pressure

8205120222 820507
 PDR ADOCK 05000255
 R PDR

ter

(9/77)

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-255

UNIT Palisades

DATE 5-7-82

COMPLETED BY DPeterscn

TELEPHONE 616 764-8913

MONTH April 1982

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u>0</u>
30	<u>0</u>
31	<u>0</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-255
 • UNIT NAME Palisades
 DATE 5-5-82
 COMPLETED BY DVanDenBerg
 TELEPHONE 616 764-8913

REPORT MONTH April 1982

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
8	820323	F	719	A	1	82-12			Steam Generator Tube Leakage

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File (NUREG-
 0161)

⁵
 Exhibit I - Same Source

SUMMARY OF OPERATING EXPERIENCE FOR THE MONTH OF APRIL 1982

The Plant was taken off line because of Steam Generator tube leakage in excess of the Technical Specification limit on March 24. Investigation and repair of the leakage continued through the end of the month of April.