

Certified By McA. Perkins 5/10/82

## BALTIMORE GAS AND ELECTRIC COMPANY

P.O. BOX 1475

BALTIMORE, MARYLAND 21203

NUCLEAR POWER DEPARTMENT  
 CALVERT CLIFFS NUCLEAR POWER PLANT  
 LUSBY, MARYLAND 20657



May 4, 1982

Mr. Ronald C. Haynes, Director  
 Office of Inspection and Enforcement  
 U. S. Nuclear Regulatory Commission  
 Region I  
 631 Park Avenue  
 King of Prussia, PA. 19406

Docket No. 50-317  
 License No. DPR-53

SUBJECT: LER 82-22/IT, Unit 1

Dear Mr. Haynes

This letter is to confirm our verbal notification of your Mr. E. B. McCabe of our discovery that from 12-18-80 until 4-18-82 all Unit 1 operations in excess of 200° have been performed with a combined leakage rate of greater than 0.60 L<sub>a</sub> for all penetrations and valves subject to Type B and C tests (T.S. 3.6.1.2.b).

At 1400 on 5-3-82 it was confirmed that an error in Surveillance Test Procedure M-571-1, Local Leak Rate Tests, caused the total measured Type B and C leak rate to be compared to L<sub>a</sub> versus 0.60 L<sub>a</sub> as required by T.S. 3.6.1.2.b.

A complete description of this event, including causes and corrective action will be addressed in a follow-up report.

Very truly yours,

*L. B. Russell*  
 L. B. Russell  
 Plant Superintendent

LBR:fld

cc: J. A. Tiernan  
 Director, Office of Management  
 Information & Program Control  
 R. B. Sydnor

R. M. Douglass  
 R. E. Architzel  
 L. B. Russell