

TO: 715-337-5324

Telephone Number

84-1882

FROM: 315-442-1110

Telephone Number

DATE/TIME

From: Niagara Mohawk Power Corporation  
Nine Mile Point Nuclear Station  
Unit #1  
P.O. Box #32  
Lycoming, New York 13093

TO: R.C. Haynes  
Regional Administrator  
USNRC Region I  
631 Park Avenue  
King of Prussia, PA. 19406

SUBJECT: PROMPT REPORTABLE OCCURRENCE  
DOCKET NO. 50-220 LICENSE NO. DPR-63  
ASSIGNED LER NO. 82-04

EVENT DATE: 2/7/82

REPORT DATE: 2/8/82

EVENT DESCRIPTION:

See Attachment

COMPONENTS INVOLVED: 115 KV Offsite Power, 102 & 103 Emergency Diesel Generators

CAUSE AND REMEDIAL ACTION:

See Attachment

FACILITY STATUS:

% THERMAL INM 1590

c) Routine Startup \_\_\_\_\_  
d) Routine Shutdown \_\_\_\_\_  
e) Steady State Oper ☒ \_\_\_\_\_  
f) Load Change \_\_\_\_\_

g) Shutdown \_\_\_\_\_  
h) Refueling \_\_\_\_\_  
i) Other \_\_\_\_\_  
j) Not Applicable \_\_\_\_\_

A written follow-up report will be sent within two weeks.

TELECOPY TO	Ronald C. Haynes	FROM	T.J. Perkins	DATE	2/8/82
	NAME		NAME		
	T.E. Lempges		"		"

ATTACHMENT TO LER 82-04 for NMP#1  
2/8/82

EVENT DESCRIPTION

A momentary loss of 115 KV offsite power caused the Emergency Diesel Generators to auto-start on low voltage to power boards 102 and 103. Loss of offsite power lasted approximately 10 seconds.

CAUSE AND REMEDIAL ACTION

During breaker exercising of system breakers, Breaker R-10 (Supply Breaker) at Southwest Oswego was opened. Redundant offsite 115 KV power source from Lighthouse Hill opened due to ground directional relay. Diesel generators 102 and 103 auto-started on loss of power to their respective power boards 102 and 103. Offsite power was restored in approximately 10 seconds.