

Certified By Ma Perkins 5/6/82TELECOPY MESSAGE
TELEPHONE MESSAGE

TO: 215-337-5324 FROM: 315-343-2110 DATE/TIME 2/5/82
 Telephone Number Telephone Number
315-475-1511 ext 1792 " " "

TO: Ronald C. Haynes
 Regional Administrator
 USNRC Region 1
 631 Park Avenue
 King of Prussia, PA. 19406

From: Niagara Mohawk Power Corporation
 Nine Mile Point Nuclear Station
 Unit #1
 P.O. Box #32
 Lycoming, New York 13093

SUBJECT: PROMPT REPORTABLE OCCURRENCE
 DOCKET NO. 50-220 LICENSE NO. DPR-63
 ASSIGNED LER NO. 82-03

EVENT DATE: 2/4/82 REPORT DATE: 2/5/82

EVENT DESCRIPTION:

SEE ATTACHMENT

COMPONENTS INVOLVED: Emergency Ventilation System

CAUSE AND REMEDIAL ACTION:

SEE ATTACHMENT

FACILITY STATUS:

% THERMAL PM 1841

c) Routine Startup _____
 d) Routine Shutdown _____
 e) Steady State Oper 2 _____
 f) Load Change _____

g) Shutdown _____
 h) Refueling _____
 i) Other _____
 j) Not Applicable _____

A written follow-up report will be sent within two weeks.

TELECOPY TO R C Haynes FROM T. J. Perkins DATE 2/5/82
T. E. Lempges NAME _____

IE29 5/11

Event Description

Cleanup sludge tank vent overflowed into Reactor Building Exhaust Ventilation System causing emergency ventilation system to initiate.

Cause and Remedial Action

During normal backwash of cleanup filter to cleanup filter sludge tank, the tank overflowed through the vent to the Reactor Building Exhaust Ventilation System. The emergency ventilation system initiated on high radiation in the reactor building exhaust duct and normal exhaust ventilation isolated. Decontamination of exhaust ductwork is in progress.