

Certified By Michael J. 5/6/92TELECOPY MESSAGE

TO: President and Chief Operating Officer
Chairman, SRC
Senior Vice-President, Nuclear Generation

TO: Director of Regulatory Operation
USNRC Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Date/Time: 2/10/82 4:20 p.m.Date/Time: 2/10/82 4:26 p.m.

FROM: Power Authority of the State of New York
James A. FitzPatrick Nuclear Power Plant
P. O. Box 41
Lycoming, New York 13093

SUBJECT: PROMPT REPORTABLE OCCURRENCE
DOCKET NO. 50-333
LICENSE NO. DPR-59
ASSIGNED OR NO. 82-013
LER NO. 82-001

EVENT DATE: 2/10/82REPORT DATE: 2/10/82

EVENT DESCRIPTION:

HPCI Steam Line Flow

Technical Specification set point appears to have been high (non-conservative) since 1974. The instrument has been calibrated in accordance with the Technical Specifications thus it was set non-conservative. (Technical Specification Table 3.2-2, Item 31, pg. 70b)

COMPONENTS INVOLVED:

23-DPIS 76 and 77

CAUSE and REMEDIAL ACTION:

Investigation in progress

FACILITY STATUS:

% THERMAL POWER 0

Routine Startup _____
Routine Shutdown _____
Steady State Power _____
Load Change _____

Shutdown _____
Refueling X _____
Other _____
Not Applicable _____

A written follow-up report will be submitted within two weeks.

8205140183 820210
PDR ADOCK 05000333
S PDR

Corbin A. McNeill, Jr.
CORBIN A. MCNEILL, JR.
RESIDENT MANAGER

IE 29
5/10