

**PSEG**

DESIGNATED ORIGINAL

Certified By M. A. Perkins 5/6/82

Public Service Electric and Gas Company P.O. Box 166 Hancocks Bridge, New Jersey 08038

Salem Generating Station

January 20, 1982

Mr. R. C. Haynes  
Director of USNRC  
Office of Inspection and Enforcement  
Region 1  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Dear Mr. Haynes:


REPORTABLE OCCURRENCE 82-02/01P  
SALEM NO. 1 UNIT LER

This letter is to confirm our verbal report to the NRC Resident Inspector at 1600 hours, January 19, 1982, advising of a potential reportable occurrence in accordance with Technical Specification 6.9.1.

During performance of surveillance requirement 4.4.5.2, defective and degraded tubes were discovered in No. 14 Steam Generator on both the first, and subsequent second inspection.

An investigation is in progress and a detailed report will be submitted pursuant to Technical Specification 6.9.1.

Sincerely yours,



H. J. Midura  
General Manager -  
Salem Operations

8205140207 820120  
PDR ADDCK 05000272  
S PDR

FD:al

CC: General Manager - Nuclear Production  
General Manager - Quality Assurance

IE29  
51/0