



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401
Telephone (612) 330-5500

May 7, 1982

Regional Administrator
Region III
U S Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137



MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

Shutdown Cooling Isolation Valve, M0-2030, Inoperable

The License Event Report for this occurrence is attached.

This event is reported in compliance with Technical Specification 3.7.D.1 since it represents operation in a degraded mode as noted by a limiting condition for operation.

L. O. Mayer for

L O Mayer, PE
Manager of Nuclear Support Services

LOM/SAF/bd

cc: NRC Document Control Desk (1)
NRC Resident Inspector
MPCA
Attn: J W Ferman

8205140213 820507
PDR ADDCK 05000263
S PDR

IE22
MAY 10 1982 51/1