

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 C T M N S 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

1 REPORT SOURCE 60 61 6 15 10 10 0 3 3 6 7 0 4 0 2 8 2 8 0 5 0 3 8 2 9
 8 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

1 The plant was in steady state operation at 95% power. During the monthly surveillance
 2 testing, the setpoint for the Reactor Coolant Pump Speed Sensing Bistable Trip, on
 3 Channel B, was found to be out of specification in a non-conservative direction. The
 4 plant was operated in accordance with action statement 2 of Technical Specification
 5 4.3.1.1.1 Similar occurrences: The following LER's all dealt with instrument
 6 drift within the General Atomic Bistable trip units, 76-48, 78-24, 79-24, 81-16.
 7

8 9

0 9
 8 9
 SYSTEM CODE 11 I A
 CAUSE CODE 12 E
 CAUSE SUBCODE 13 G
 COMPONENT CODE 14 I N S T R U
 COMP SUBCODE 15 X
 VALVE SUBCODE 16 Z
 LER NO. 17 8 2
 EVENT YEAR 21 22
 SEQUENTIAL REPORT NO. 24 26 0 0 8
 OCCURRENCE CODE 28 29 0 3
 REPORT TYPE 30 L
 REVISION NO. 32 0
 ACTION TAKEN 33 E
 FUTURE ACTION 34 A
 EFFECT ON PLANT 35 Z
 SHUTDOWN METHOD 36 Z
 HOURS 37 0 0 0 0
 ATTACHMENT SUBMITTED 41 N
 NRC-4 FORM SUB. 42 Y
 PRIME COMP. SUPPLIER 43 N
 COMPONENT MANUFACTURER 44 G 0 6 3 47 26
 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of the out of specification setpoint was instrument drift within the General
 1 1 Atomic Bistable trip unit, ELD-240-000. The Bistable was adjusted to trip within the
 1 2 allowable tolerances. The General Atomic Bistable trip units will be replaced with a
 1 3 Bistable trip unit which is less susceptible to drift.
 1 4

7 8 9

1 5 FACILITY STATUS 28 E
 % POWER 10 12 0 9 5 29
 OTHER STATUS 30 NA
 METHOD OF DISCOVERY 31 B
 DISCOVERY DESCRIPTION 32 Surveillance Testing

1 6 ACTIVITY RELEASED 33 Z
 CONTENT OF RELEASE 34 Z
 AMOUNT OF ACTIVITY 35 NA
 LOCATION OF RELEASE 36 NA

1 7 PERSONNEL EXPOSURES NUMBER 37 0 0 0
 TYPE 38 Z
 DESCRIPTION 39 NA

1 8 PERSONNEL INJURIES NUMBER 40 0 0 0
 DESCRIPTION 41 NA

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE 42 Z
 DESCRIPTION 43 NA

2 0 PUBLICITY DESCRIPTION 45
 ISSUED 44 N
 8205140266 820503
 PDR ADOCK 05000336
 S PDR
 NRC USE ONLY
 68 69

NAME OF PREPARER Keith D. Deslandes PHONE 447-1791 Ext. 4421