

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONTROL BLOCK: 1 2 3 4 5 6 1

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

REPORT SOURCE: L 6 0 5 0 0 0 3 3 6 7 0 4 0 5 8 2 8 0 5 9 5 8 2 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

With the reactor at 8% power during a plant startup, Reactor Coolant System Temperature (Tavg) decreased to 514°F. The facility operated in accordance with Technical Specifications Action Statement 3.1.1.5 for approximately 3 minutes.

Similar LER's: None

SYSTEM CODE: C B 11
CAUSE CODE: A 12
CAUSE SUBCODE: A 13
COMPONENT CODE: Z Z Z Z Z Z 14
COMP. SUBCODE: Z 15
VALVE SUBCODE: Z 16
EVENT YEAR: 8 2
SEQUENTIAL REPORT NO.: 0 1 1 1
OCCURRENCE CODE: 0 3
REPORT TYPE: L
REVISION NO.: 0
LER/RO REPORT NUMBER: 17
ACTION TAKEN: H 18
FUTURE ACTION: Z 19
EFFECT ON PLANT: Z 20
SHUTDOWN METHOD: Z 21
HOURS: 0 0 0 0
ATTACHMENT SUBMITTED: Y 23
NPRD-4 FORM SUB.: N 24
PRIME COMP. SUPPLIER: Z 25
COMPONENT MANUFACTURER: Z 9 9 9 9 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

With a positive moderator temperature coefficient, boration to control Xenon while placing the turbine on line, caused a power reduction and cooldown which caused a further power reduction. CEA's were withdrawn to increase power and temperature. Operators have been instructed to be aware of plant conditions and core characteristics.

FACILITY STATUS: C 28
% POWER: 0 0 8 29
OTHER STATUS: NA 30
METHOD OF DISCOVERY: A 31
DISCOVERY DESCRIPTION: Operator observation 32

ACTIVITY CONTENT RELEASED: Z 33
AMOUNT OF ACTIVITY: NA 35
LOCATION OF RELEASE: NA 36

PERSONNEL EXPOSURES: 0 0 0 37
TYPE: Z 38
DESCRIPTION: NA 39

PERSONNEL INJURIES: 0 0 0 40
DESCRIPTION: NA 41

LOSS OF OR DAMAGE TO FACILITY: Z 42
DESCRIPTION: NA 43

PUBLICITY: N 44
ISSUED: N 44
DESCR: S
NAME OF PREPARER: John Resetar
PHONE: (203) 447-1791

NRC USE ONLY