

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8	9	14						15	25								26	30				57	58				
LICENSEE CODE		LICENSE NUMBER														LICENSE TYPE				CAT								

CON'T

REPORT SOURCE 0 1 7 8 L 6 0 5 0 - 0 3 2 4 7 0 3 3 0 8 2 8 0 4 2 8 8 2 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During plant operation, the RCIC System automatically isolated due to the receipt
0 3 of a spurious steam leak detection differential temperature "A" channel isolation
0 4 signal. In accordance with technical specifications, an LCO was initiated on the
0 5 RCIC System. This event did not affect the health and safety of the public.
0 6
0 7
0 8 Technical Specifications 3.3.2, 3.7.4, 6.9.1.9b

09		SYSTEM CODE S D 11		CAUSE CODE X 12		CAUSE SUBCODE Z 13		COMPONENT CODE Z Z Z Z 14				COMP. SUBCODE Z 15		VALVE SUBCODE Z 16			
7	8	9	10	11	12	13	14	15	16	17	18	19	20				
17 LER/RO REPORT NUMBER		EVENT YEAR 8 2 21 22		SEQUENTIAL REPORT NO. 0 3 5 24 26		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30		REVISION NO. 0 32							
ACTION TAKEN Z 18 33		FUTURE ACTION Z 19 34		EFFECT ON PLANT Z 20 35		SHUTDOWN METHOD Z 21 36		HOURS 0 0 0 0 22 37 40		ATTACHMENT SUBMITTED N 23 41		NPRD-4 FORM SUB. Y 24 42		PRIME COMP. SUPPLIER Z 25 43		COMPONENT MANUFACTURER Z 9 9 9 9 26 44 47	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of the isolation signal is unknown. Performance of the RCIC System

1 1 isolation channel functional and operability test, PT-02.1.9P, did not reveal any

1 2 instrumentation operability problems. The isolation signal was reset and the

1 3 RCIC System was returned to normal standby readiness. It is felt that the monthly

1 4 performance of PT-02.1.9P will help detect any instrumentation failures.

FACILITY STATUS [1][5] [E](28)	% POWER [0][7][5](29)	OTHER STATUS NA(30)	METHOD OF DISCOVERY A(31) Operational Event	DISCOVERY DESCRIPTION (32)
ACTIVITY CONTENT RELEASED OF RELEASE [1][6] [Z](33) [Z](34)	AMOUNT OF ACTIVITY NA(35)		LOCATION OF RELEASE NA(36)	
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION [1][7] [0][0][0](37) Z(38)		DESCRIPTION NA(39)		
PERSONNEL INJURIES NUMBER DESCRIPTION [1][8] [0][0][0](40)		DESCRIPTION NA(41)		
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION [1][9] [Z](42)		DESCRIPTION NA(43)		
PUBLICITY ISSUED DESCRIPTION [2][0] N(44)		DESCRIPTION NA(45)	NRC USE ONLY	

NRC USE ONLY

8205 NAME OF PREPARER 180268

M. J. Pastva, Jr.

PHONE: 919-457-9521