

REGION II
TENNESSEE VALLEY AUTHORITY
CHATTANOOGA, TENNESSEE 37401

1750 Chestnut Street Tower II

82 MAY 13 4:31

May 11, 1982

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 1 - DOCKET
NO. 50-327 - FACILITY OPERATING LICENSE DPR-77 - REPORTABLE OCCURRENCE
REPORT SQRO-50-327/82050

The enclosed report provides details concerning the inoperability of diesel generator 1A-A. This event required entry into the action statement of limiting condition for operation 3.8.1.1 and is reportable under Sequoyah unit 1 Technical Specification 6.9.1.13.b. This has been evaluated for reportability under 10 CFR 21 and is not reportable.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. A. Green
J. J. Green

Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Records Center
Institute of Nuclear Power Operations
1820 Water Place
Atlanta, Georgia 30339

NRC Inspector, Sequoyah

8205180390S

An Equal Opportunity Employer

OFFICIAL COPY

IE 22
S 1/1