

**LICENSEE EVENT REPORT**

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8	9						14	15	25								26	30					57	CAT	58		
		LICENSEE CODE							LICENSE NUMBER									LICENSE TYPE										

CONT

REPORT SOURCE L 6 0 5 0 - 0 3 2 4 7 0 4 0 7 8 2 8 0 5 0 6 8 2 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During plant operation, the CRD accumulator high water level annunciation was  
0 3 | received for hydraulic control unit (HCU) No. 30-43. The subject HCU was then  
0 4 | declared inoperable in accordance with technical specifications. This event did  
0 5 | not affect the health and safety of the public.  
0 6 | Technical Specifications 3.1.3.5, 6.9.1.9b  
0 7 |  
0 8 |

0	9	SYSTEM CODE		R	B	11	CAUSE CODE		X	12	CAUSE SUBCODE		Z	13	COMPONENT CODE						Z	Z	Z	Z	Z	Z	14	COMP. SUBCODE		Z	15	VALVE SUBCODE		Z	16					
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.		ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER												
8		2		0		6	6	L		0		0		3	L		0		—		0		0	0	0	N		Y		N		G		0	8	0				

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The annunciation is attributed to a high water level in the HCU caused by leakage  
1 1 around the HCU piston seals. The water level in the HCU was reduced to reset the  
1 2 annunciation and the HCU was returned to service within one hour and twenty minutes  
1 3 of the event. This is considered an isolated occurrence and no further action is  
1 4 planned.

FACILITY STATUS										% POWER				OTHER STATUS				METHOD OF DISCOVERY		DISCOVERY DESCRIPTION									
1	5	E	28	0	8	2	29	NA				A	31	Operational Event															
ACTIVITY CONTENT										AMOUNT OF ACTIVITY										LOCATION OF RELEASE									
1	6	Z	33	Z	34	NA				NA																			
PERSONNEL EXPOSURES										DESCRIPTION																			
1	7	0	0	0	37	Z	38	NA																					
PERSONNEL INJURIES										DESCRIPTION																			
1	8	0	0	0	40	NA																							
LOSS OF OR DAMAGE TO FACILITY										DESCRIPTION																			
1	9	Z	42	NA																									
PUBLICITY										DESCRIPTION										NRC USE ONLY									
2	0	N	44	NA																									

82051803975 M. J. Pastva, Jr.  
NAME OF PREPARER

PHONE 919-457-9521