

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 SCNEE1 200-000000-00 341111 4 5
7 8 9 LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 58

CON'T
01 REPORT SOURCE L 505000269 7040782 8050782 9
7 8 9 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On April 7, 1982, valve 1LWD-1 did not close after pumping the Reactor Building
03 normal sump. This valve is the Reactor Building isolation valve for the Reactor
04 Building normal sump; thus, this event is a degraded mode per Technical Specifi-
05 cation 3.6.3.b. The redundant isolation valve was locked shut within one hour
06 and valve 1LWD-1 was repaired and declared operable within four hours; thus, the
07 health and safety of the public were not affected by this incident.
08
09

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
09 S D 11 E 12 D 13 CK T B R K 14 B 15 Z 16
7 8 9 10 11 12 13 14 15 16 17 18

17 LER/RO REPORT NUMBER 82 21 22
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
18 B 19 G 20 Z 21 Z 22 0000 Y 23 N 24 L 25 L 26 C 27 O 28
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The apparent cause of this occurrence was a dirty contact in the valve operating
11 motor starting compartment. The contact was cleaned and the valve cycled
12 satisfactorily. The preventive maintenance procedure has been modified to re-
13 quire specific visual inspection of the contacts, and cleaning of the contacts
14 as necessary.
15

FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
15 E 28 1100 29 NA 30 A 31 Operator Observation
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
16 Z 33 Z 34 NA 35 NA 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION
17 000 37 Z 38 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

PERSONNEL INJURIES NUMBER DESCRIPTION
18 000 40 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION
19 Z 42 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

PUBLICITY ISSUED DESCRIPTION
20 N 44 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

NRC USE ONLY
58 59 60

NAME OF PREPARED J. F. Kutzer
8205180424
PHONE: (704) 373-7139