

CONTROL BLOCK: 

--	--	--	--	--	--

 (3) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
---	---

REPORT SOURCE

L	6	0	5	0	0	0	2	7	2	7	0	4	2	2	8	2	8	0	5	0	5	8	2	2
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

DOCKET NUMBER

EVENT DATE

REPORT DATE

0 2 On April 22, 1982, during surveillance testing, it was discovered that No. 2 Fire  
0 3 Pump did not start in the automatic mode. No. 2 Fire Pump was declared inoperable  
0 4 and at 1115 hours, Action Statement 3.7.10.1.a was entered. At 1115 hours, April  
0 5 29, 1982, No. 2 Fire Pump was still inoperable. This occurrence was therefore  
0 6 reportable in accordance with Technical Specification 6.9.2.f, Special Reports  
0 7 for Fire Suppression Systems.

SYSTEM CODE A B		CAUSE CODE E		CAUSE SUBCODE B		COMPONENT CODE X X X X X					COMP. SUBCODE Z		VALVE SUBCODE Z	
11		12		13		14					15		16	
EVENT YEAR 8 2		SEQUENTIAL REPORT NO. 0 2 7		OCCURRENCE CODE 9 9		REPORT TYPE X		REVISION NO. 0						
21		22		23		24		25		26		27		
ACTION TAKEN B		FUTURE ACTION Z		EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0 0 0 0		ATTACHMENT SUBMITTED Y		NPRD-4 FORM SUB. Y		
18		19		20		21		22		23		24		
PRIME COMP. SUPPLIER N		COMPONENT MANUFACTURER W 0 5 9												
25		26												

1 0 No. 2 Fire Pump had failed to start due to a damaged flywheel. A redundant water  
1 1 supply was available via the crosstie line to Hope Creek Station. The flywheel on  
1 2 No. 2 Fire Pump was properly repaired, and the pump was satisfactorily tested.  
1 3 At 2158 hours, May 1, 1982, the pump was declared operable, and Action Statement  
1 4 13.7.10.1.a was terminated.

7	8	9	FACILITY STATUS 1 5 C 28	% POWER 0 0 0 29	OTHER STATUS N/A 30	METHOD OF DISCOVERY B 31	DISCOVERY DESCRIPTION Surveillance Testing 32	80
7	8	9	ACTIVITY CONTENT RELEASED OF RELEASE 1 6 Z 33	Z 34	AMOUNT OF ACTIVITY N/A 35	LOCATION OF RELEASE N/A 36	80	
7	8	9	PERSONNEL EXPOSURES NUMBER 1 7 0 0 0 37	TYPE Z 38	DESCRIPTION N/A 39	80		
7	8	9	PERSONNEL INJURIES NUMBER 1 8 0 0 0 40	DESCRIPTION N/A 41	80			
7	8	9	LOSS OF OR DAMAGE TO FACILITY TYPE 1 9 Z 42	DESCRIPTION N/A 43	80			
7	8	9	PUBLICITY ISSUED 2 0 N 44	DESCRIPTION N/A 45	NRC USE ONLY 68 69 80			

NAME OF PREPARER

R. Frahm

PHONE: (609) 541-5900 629

8 9 10  
8205180450 NAME OF PREPARER