



Harry Tauber
Vice President
Engineering and Construction

2000 Second Avenue
Detroit, Michigan 48226
(313) 237-8000

May 12, 1982
EF2 - 57,430

Mr. B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Youngblood:

References: 1. Enrico Fermi Atomic Power Plant, Unit 2
NRC Docket No. 50-341
2. Letter B. J. Youngblood to H. Tauber
dated February 24, 1982

Subject: Operability of Containment Purge
Valves for Fermi 2

Responses for the three (3) items listed in the referenced letter are provided in this memorandum. These responses, along with our previous submittals, fully address the purge valve operability issue.

1. A commitment to modify the valve and valve disc orientations is contained in our letter of January 4, 1982 (EF2-55,980). The valves are punchlisted as incorrectly installed, and the installation modification is in progress (SU-8258 and EF2-57,112).
2. Table 3.6.3-1 of the Technical Specifications contains the inservice inspection information for these valves.
3. The valve will operate automatically even in the manual handwheel mode. The handwheel clutch is disengaged when this occurs.

Should you have any questions, please call Mr. L. E. Schuerman, (313) 649-7562.

Sincerely,

cc: L. L. Kintner
B. Little

8205180458

A

Handwritten notes: "Aona", "D", "S", "1/1"