

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II, 31

82 MAY 13
May 11, 1982

BLRD-50-438/82-28

BLRD-50-439/82-25

U.S. Nuclear Regulatory Commission

Region II

ATTN: James P. O'Reilly, Regional Administrator

101 Marietta Street, Suite 3100

Atlanta, Georgia 30303

Dear Mr. O'Reilly:


BELLEFONTE NUCLEAR PLANT UNITS 1 AND 2 - VALVES NOT QUALIFIED TO APPLICABLE
DESIGN REQUIREMENTS BLRD-50-438/82-28, BLRD-50-439/82-25 - FIRST INTERIM
REPORT

The subject deficiency was initially reported to NRC-OIE Inspector
R. V. Crlenjak on April 12, 1982 in accordance with 10 CFR 50.55(e) as NCRs
BLN BLP 8214 and BLN BLP 8215. Enclosed is our first interim report. We
expect to submit our next report by August 18, 1982.

If you have any questions, please get in touch with R. H. Shell at FTS
858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY


L. M. Mills, Manager
Nuclear Licensing

Enclosure

cc: Mr. Richard C. DeYoung, Director (Enclosure)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

8205180467

S

OFFICIAL COPY

IE 27

5/11

ENCLOSURE

BELLEFONTE NUCLEAR PLANT UNITS 1 AND 2
VALVES NOT QUALIFIED TO APPLICABLE DESIGN REQUIREMENTS
10 CFR 50.55(e)
NCRs BLN BLP 8214 AND BLN BLP 8215
BLRD-50-438/82-28, BLRD-50-439/82-25
FIRST INTERIM REPORT

Description of Deficiency

The 3-inch containment isolation and test valves, manufactured by Target Rock Valve Company, East Farmingdale, New York (VSEB-018-N and VSEB-019-N) and the 4-inch auxiliary feedwater pressure control valves, manufactured by YARWAY Corporation, Blue Bell, Pennsylvania (VSEC-046-A and VSEC-047-B) indicated on nonconformance report Nos. BLN BLP 8214 and BLN BLP 8215, respectively, were purchased as nonactive components. These valves should be active components.

Interim Progress

TVA will have the valve manufacturers qualify the existing valves as active components.