

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

COMPONENT
MANUFACTURER
A 4 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

The Asco Solenoid, Cat. No. 8317A35 was operating improperly and did not allow normal bleed-off of the air supply which would close the 3-1601-55 valve. The solenoid was replaced and the valve was retested with acceptable closure time. The valve timing surveillance will continue to be performed quarterly.

PHONE:



Commonwealth Edison

DEVIATION REPORT

DVR NO.

12 3 82 26
STA UNIT YEAR NO.

PART 1 TITLE OF DEVIATION Failure of Nitrogen Inerting
Stop Valve to Close Within Required Time

OCCURRED

4/14/82

2145

DATE

TIME

SYSTEM AFFECTED 1600
Primary Containment

PLANT STATUS AT TIME OF EVENT

MODE Shutdown

PWR(MWT) 0

LOAD(MWE) 0

TESTING

☒ YES☐ NO

DESCRIPTION OF EVENT

While performing DOS 1600-1 (Quarterly Valve Timing) valve 1601-55

failed to close in less than or equal to 15 seconds as required by Tech. Spec. Table 3.7.1.

The reactor was in cold shutdown at the time.

10 CFR50.72 NRC RED PHONE

☐☒

NOTIFICATION MADE

YES

NO

EQUIPMENT FAILURE

D19867

☒ YES☐ NO

WORK REQUEST NO.

RESPONSIBLE SUPERVISOR

W. Pietryga

DATE 4/14/82

PART 2 OPERATING ENGINEER'S COMMENTS

The valve will be satisfactorily tested following repairs

prior to unit startup from the spring 1982 refueling outage.

☐ EVENT OF PUBLIC INTEREST☐ TECH. SPEC. VIOLATION☐ NON REPORTABLE OCCURRENCE☐ 14 DAY REPORTABLE/T.S.☒ 30 DAY REPORTABLE/T.S. 6.6.B.2.b☐ ANNUAL/SPECL REPORT REQ'D☐ 24-HOUR NRC NOTIFICATION REQ'D

TELEPH Tom Tongue (courtesy)

4/15/82

0930

REGION III

DATE

TIME

TELEGM/TELECOPY

REGION III

DATE

TIME

☐ CECO CORPORATE NOTIFICATION MADE

IF ABOVE NOTIFICATION IS PER 10CFR21

☐ 5-DAY WRITTEN REPORT REQ'D PER 10CFR21

F. A. Palmer

4/19/82

1204

TELEPH

CECO CORPORATE OFFICER

DATE

TIME

PRELIMINARY REPORT
COMPLETED AND REVIEWED

Michael Wright

OPERATING ENGINEER

4/15/82

DATE

INVESTIGATED REPORT & RESOLUTION
ACCEPTED BY STATION REVIEW

Jack Brunner

5/5/82

John W. Wiggins

5/5/82

RESOLUTION APPROVED AND
AUTHORIZED FOR DISTRIBUTION

Douglas Hunt

STATION SUPERINTENDENT

5/7/82

DATE