

MAY 12 1982

Docket No. 50-334  
CAL No. 82-18

Duquesne Light Company  
ATTN: Mr. J. J. Carey  
Vice President  
Nuclear Division  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Gentlemen:

This letter refers to the deficiencies identified during your initial installation and testing of the Prompt Notification System. The final rule as published in the Federal Register (46FR63032) on December 30, 1981 provides up to four months for correction of deficiencies identified during the initial installation and testing.

As discussed during a conversation with Mr. John Maracek of your staff and Ms. M. Mojta of this office on May 5, 1982, we understand that you will correct the identified deficiencies prior to June 1, 1982. These actions include repairing or replacing motors on sirens that show evidence of smoking. Please inform this office in writing when the deficiencies have been corrected.

If our understanding of your planned actions described above is not in accordance with your actual plans and actions being implemented, please contact H. W. Crocker of this office by telephone (215) 337-5000, within 24 hours of your receipt of this letter.

As you are aware, the Federal Emergency Management Agency (FEMA) has the responsibility to determine the adequacy of the Prompt Notification System. Acceptance criteria are being developed.

The responses directed by this letter are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

Your cooperation with us on this matter is appreciated.

Sincerely,

Original Signed By:

George H. Smith, Director,  
Division of Emergency Preparedness and  
Operational Support

OFFICIAL RECORD COPY

8205180503

F

10 35  
1/1

Original filed 5/12

MAY 1 2 1982

cc:

F. Bissert, Manager, Nuclear Support Services  
R. Washabaugh, QA Manager  
H. P. Williams, Station Superintendent  
W. S. Lacey, Chief Engineer  
R. Martin, Nuclear Engineer  
J. Sieber, Manager, Nuclear Safety and Licensing  
T. Jones, Manager, Nuclear Operations  
R. M. Mafrice, Nuclear Engineer  
N. R. Tonet, Manager, Nuclear Engineering  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
Commonwealth of Pennsylvania  
NRC Resident Inspector

bcc:

Region I Docket Room (with concurrences)

RI:DEPOS  
Wajta/gwc  
5/10/82

RI:DEPOS  
Snyder  
5/10/82

RI:DEPOS  
Smith  
5/11

RE:STAFF  
BARON  
5/12

OFFICIAL RECORD COPY