

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK / / / / / / (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

/0/1/ /V/A/N/A/S/1/ (2) /0/0/-/0/0/0/0/0/-/0/0/ (3) /4/1/1/1/1/ (4) / / / (5)
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

/0/1/ REPORT /L/ (6) /0/5/0/0/0/3/3/8/ (7) /0/4/0/8/8/2/ (8) /0/5/0/3/8/2/ (9)
 SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

/0/2/ / On April 8, 1982, during Mode 1 operation, the containment personnel hatch inner /
 /0/3/ / door seals did not meet the Acceptance Criteria of the surveillance test. In /
 /0/4/ / addition, the outer door seals failed as a result of the operation of the door /
 /0/5/ / made necessary by the inner door test. Since the door seals were repaired with- /
 /0/6/ / in 24 hours and only a small amount of leakage occurred into the containment, the /
 /0/7/ / health and safety of the general public were not affected. This event is report- /
 /0/8/ / able pursuant to T.S. 6.9.1.9.b. /

SYSTEM CAUSE CAUSE COMP. VALVE
 CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCODE

/0/9/ /S/A/ (11) /E/ (12) /F/ (13) /P/E/N/E/T/R/ (14) /A/ (15) /Z/ (16)
 LER/RO EVENT YEAR SEQUENTIAL OCCURRENCE REPORT REVISION
 (17) REPORT REPORT NO. CODE TYPE NO.
 NUMBER /8/2/ /-/ /0/1/8/ / \ / /0/3/ /L/ /-/ /0/

ACTION FUTURE EFFECT SHUTDOWN ATTACHMENT NPRD-4 PRIME COMP. COMPONENT
 TAKEN ACTION ON PLANT METHOD HOURS SUBMITTED FORM SUB. SUPPLIER MANUFACTURER
 /A/ (18) /Z/ (19) /Z/ (20) /Z/ (21) /0/0/0/0/ (22) /Y/ (23) /N/ (24) /A/ (25) /C/3/1/0/ (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

/1/0/ / The cause of the seal failures was excessive drying of the seal material causing /
 /1/1/ / improper seating. The outer door seal failed after operating the door to perform /
 /1/2/ / the inner door seal test. The inner door seal was lubricated and the outer door /
 /1/3/ / seal replaced. /
 /1/4/ / /

FACILITY METHOD OF
 STATUS %POWER OTHER STATUS DISCOVERY DISCOVERY DESCRIPTION (32)
 /1/5/ /E/ (28) /1/0/0/ (29) / NA / (30) /B/ (31) / Surveillance Test /

ACTIVITY CONTENT
 RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
 /1/6/ /Z/ (33) /Z/ (34) / NA / / NA /

PERSONNEL EXPOSURES
 NUMBER TYPE DESCRIPTION (39)
 /1/7/ /0/0/0/ (37) /Z/ (38) / NA /

PERSONNEL INJURIES
 NUMBER DESCRIPTION (41)
 /1/8/ /0/0/0/ (40) / NA /

LOSS OF OR DAMAGE TO FACILITY (43)
 TYPE DESCRIPTION
 /1/9/ /Z/ (42) / NA /

PUBLICITY
 ISSUED DESCRIPTION (45)
 /2/0/ /N/ (44) / NA /

NRC USE ONLY

/ / / / / / / / / / / / / /

8205180518

NAME OF PREPARER

W. R. CARTWRIGHT

PHONE (703) 894-5151