

McGUIRE NUCLEAR STATION

Operating Status Report

1. Personnel Exposure

For the month of March, 1 individual(s) exceeded 10 percent of their allowable annual radiation dose limit with the highest dose being 1.240 rem, which represents approximately 10.3% of that person's allowable annual limit.

2. The total station liquid release contribution to whole body dose for March has been compared with the Technical Specifications annual value of 3 mrem; the total release for March was less than 10 percent of this limit.

The total station gaseous release contribution to any organ dose for March has been compared with the derived Technical Specifications annual value of 15 mrem; the total release for March was less than 10 percent of this limit.