

TENNESSEE VALLEY AUTHORITY
CHATTANOOGA, TENNESSEE 37402
1750 Chestnut Street Tower II

82 APR 29 4:46

April 27, 1982

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 3 - DOCKET
NO. 50-296 - FACILITY OPERATING LICENSE DPR-68 - REPORTABLE OCCURRENCE
REPORT BFRO-50-296/82011

The enclosed report provides details concerning reactor protection system
water level switches which were found with setpoints outside technical
specification limits. This report is submitted in accordance with Browns
Ferry unit 3 Technical Specification 6.7.2.a(5).

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. A. Green
H. J. Green

Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Records Center
Institute of Nuclear Power Operations
1820 Water Place
Atlanta, Georgia 30339

NRC Inspector, Browns Ferry

8205210127 820427
PDR ADOCK 05000296
S PDR

An Equal Opportunity Employer

1222
11