

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE				30	57	CAT 58	

REPORT
SOURCE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During plant operation, while performing the channel calibration and operability test
0 3 | of drywell hydrogen and oxygen monitoring instrumentation, PT-55.4PC, drywell
0 4 | hydrogen analyzer, 2-CAC-AT-1263-1, indicated properly in response to an applied test
0 5 | signal but failed to actuate the "Containment Atmospheric Oxygen-Hydrogen High"
0 6 | annunciator as required. This event did not affect the health and safety of the
0 7 | public.

08 Technical Specifications 3.3.5.3, 3.6.6.4, 6.9.1.9b 80

SYSTEM CODE S E 11		CAUSE CODE B 12		CAUSE SUBCODE B 13		COMPONENT CODE I N S T R U 14		COMP. SUBCODE X 15		VALVE SUBCODE Z 16	
7 8		9 10		11 12		13 14		15 16		17 18	
17 LER/RO REPORT NUMBER		EVENT YEAR 8 2 21 22		SEQUENTIAL REPORT NO. 0 6 8 24 26		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30		REVISION NO. 0 32	
ACTION TAKEN B 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22 40		ATTACHMENT SUBMITTED N 23	
33 34		35 36		37 38		39 40		41 42		43 44	
NPRD-4 FORM SUB. Y 24		PRIME COMP. SUPPLIER A 25		COMPONENT MANUFACTURER B 1 3 5 26							
45 46		47 48		49 50		51 52		53 54		55 56	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 A bad solder joint in the 1263-1 alarm actuation potentiometer circuitry, attributed
1 1 to a manufacturing defect, prevented actuation of the annunciator. The solder joint
1 2 was re-soldered and the PT was satisfactorily completed. The 1263-1 analyzer,
1 3 Model No. 7C6A, was then returned to normal service. No further action to this
1 4 event is required.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION				
1	5	E	28	0	8	2	29	NA	B	31	Periodic Test	32
7	8	9		10	11	12	13	44	45	46		80

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 2 33 2 34

7 8 9 10 11

AMOUNT OF ACTIVITY (35)

NA

44

LOCATION OF RELEASE (36)

NA

45 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	NA

7		8		9		10		11		12		13		14		15		16		17		18		19		20		21		22		23		24		25		26		27		28		29		30		31		32		33		34		35		36		37		38		39		40		41		42		43		44		45		46		47		48		49		50	
LOSS OF OR DAMAGE TO FACILITY (43)																																																																																							
TYPE DESCRIPTION																																																																																							
1		9		Z		(42)		NA																																																																															

7 8 9 10 80
PUBLICATION
ISSUED DESCRIPTION (4) 8205210129 820504
2 0 N 44 PDR ADOCK 05000324
S PDR NA
7 8 9 10 68 69 80
NRC USE ONLY

NAME OF PREPARER M. J. Pastva, Jr.

PHONE: 919-457-9521