

(7-77)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7 8 9 14 15 25 26 30 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

0 1 A L B R F 3 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

CON'T

REPORT SOURCE: 0 1 L 6 0 5 0 0 0 2 9 6 7 0 4 0 6 8 2 8 0 5 0 5 8 2 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During refueling outage on unit 3 and during routine performance of SI 4.2.F-10
0 3 | (Drywell Pressure) revealed that pressure switch 3-PS-64-67 had an as-found
0 4 | calibration of 35.5 psig. Technical Specification Table 3.2.F requires an
0 5 | alarm at 35 psig. There was no danger to the health or safety of the public
0 6 | because redundant drywell pressure switches at lower setpoints were available
0 7 | and operable.

[illegible]

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 5 | Pressure switch 3-PS-64-67 setpoint had drifted. The GE model 50-560-111AAAC1

1 1 | alarm unit was immediately recalibrated, functionally tested, and returned to

1 2 | service. This is considered a random event and no further recurrence control is

1 3 | planned.

1	4														
7	8	9													
FACILITY STATUS			% POWER			OTHER STATUS			METHOD OF DISCOVERY			DISCOVERY DESCRIPTION			
1	5	G	28	0	0	0	29	NA			B	31	Surveillance testing		
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22

ACTIVITY CONTENT

RELEASED OF RELEASE

AMOUNT OF ACTIVITY (35)

LOCATION OF RELEASE (36)

1 6 Z 33 Z 34 NA NA

7 8 9 10 11 44 45

PERSONNEL EXPOSURES									
NUMBER			TYPE		DESCRIPTION				
1	7	0	0	0	(37)	2	(38)	NA	

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	2	3	4
0	0	0	(4)

NA

8205210218 820505
238 4226K 05000296

NRC USE ONLY

8205210218 820505
PDR ADDCK 05000296
S PDR

NAME OF PREPARER B. J. Irby

PHONE (205) 729-0841

LER SUPPLEMENTAL INFORMATION

BFRO-50- 296 / 8210 Technical Specification Involved Table 3.2.F

Reported Under Technical Specification 6.7.2.b.(2) * Date Due NRC 5/6/82

Event Narrative:

Units 1 and 2 were in normal operation and unit 3 was in a refueling outage. Only unit 3 was affected by this event. While performing Surveillance Instruction (SI) 4.2.F-10 (Drywell Pressure), pressure switch 3-PS-64-67 operated at 35.5 psig. Technical Specification Table 3.2.F requires the switch to operate at 35 psig. The function of 3-PS-64-67 is to initiate the alarm "Initiate Containment Spray" under accident conditions. The switch was immediately recalibrated per SI 4.2.F-10 and returned to service. There was no danger to the health or safety of the public, plant employees, or equipment at anytime because redundant drywell pressure switches at lower setpoints were available and operable. This event is considered random, and no further recurrence control is planned.

* Previous Similar Events:

296/81054

Retention: Period - Lifetime; Responsibility - Document Control Supervisor

*Revision: JRP