

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONT

0	1
---	---

REPORT SOURCE

L	6	0	5	0	0	0	2	5	1	7	0	4	1	4	8	2	3	0	5	1	2	8	2	9	
80	83								88	89						74	75							80	
		ROCKET NUMBER										EVENT DATE										REPORT DATE			

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

012 | While operating at 100% power, the operators received a low level alarm  
013 | for the condensate storage tank. While attempting to fill the tank, the  
014 | level fell below the minimum acceptable level of 185,000 gallons. This is  
015 | reportable in accordance with Technical Specifications 3.8.1.C. The health  
016 | and safety of the public was not affected. Similar occurrences were  
017 | reported as LERs 251-79-17, 251-80-02, 251-80-04, 251-81-01, 251-81-16,  
018 | 250-79-29 and 250-80-02.

SYSTEM CODE [ 0 ] [ 9 ]		CAUSE CODE [ W ] [ F ] (11)		CAUSE SUBCODE [ D ] (12)		COMPONENT CODE [ Z ] [ Z ] [ Z ] [ Z ] [ Z ] [ Z ] (13) [ 14 ]		COMP SUBCODE [ Z ] (15)		VALVE SUBCODE [ Z ] (16)	
(17) LER/RO REPORT NUMBER [ 8 ] [ 2 ]		EVENT YEAR [ 8 ] [ 2 ]		SEQUENTIAL REPORT NO. [ 0 ] [ 0 ] [ 5 ]		OCCURRENCE CODE [ / ]		REPORT TYPE [ L ]		REVISION NO. [ 0 ]	
ACTION TAKEN [ G ] (18)		FUTURE ACTION [ Z ] (19)		EFFECT ON PLANT [ Z ] (20)		SHUTDOWN METHOD [ Z ] (21)		HOURS [ 0 ] [ 0 ] [ 0 ] [ 0 ] (22)		ATTACHMENT SUBMITTED [ N ] (23)	
								NPRD-4 FORM SUB [ N ] (24)		PRIME COMP SUPPLIER [ Z ] (25)	
										COMPONENT MANUFACTURER [ X ] [ 9 ] [ 9 ] [ 9 ] (26)	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Manual Valve DWDS - 001 to the new DMWST was open, allowing a path to the

1 1 demineralized water storage tank. When CV-1540 was opened to fill the CST,

1 2 the water went to the DMWST instead because it was at a lower elevation.

1 3 The valves were re-aligned and the CST was filled to an acceptable level in

1 4 less than one hour.

FACILITY STATUS			% POWER			OTHER STATUS			METHOD OF DISCOVERY			DISCOVERY DESCRIPTION		
1	5	E	1	0	0	NA			A	Operator Observation				
ACTIVITY CONTENT						AMOUNT OF ACTIVITY			LOCATION OF RELEASE					
RELEASED OF RELEASE			Z			NA			NA					
PERSONNEL EXPOSURES			NUMBER			TYPE			DESCRIPTION					
1	7	0	0	0	0	Z			NA					
PERSONNEL INJURIES			NUMBER			DESCRIPTION								
1	2	0	0	0	0	NA								
LOSS OF OR DAMAGE TO FACILITY			TYPE			DESCRIPTION								
1	9	Z	NA											
PUBLICITY			ISSUED			DESCRIPTION			NRC USE ONLY					
2	0	N	NA											

NAME OF PREPARER P.L. Pace

PHONE (305) 552-3654