

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

1750 Chestnut Street Tower II

USNRC REGION II
ATLANTA, GEORGIA
82 MAY 6 4 5: 39

May 5, 1982

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303


Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 3 - DOCKET
NO. 50-296 - FACILITY OPERATING LICENSE DPR-68 - REPORTABLE OCCURRENCE
REPORT BFRO-50-296/82009

The enclosed report provides details concerning operation of primary
containment and reactor building isolation instrumentation low pressure
main steam line pressure switches outside of limits because of setpoint
drift. This report is submitted in accordance with Browns Ferry unit 3
Technical Specification 6.7.2.b.1.

Very truly yours,

TENNESSEE VALLEY AUTHORITY


H. J. Green
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Records Center
Institute of Nuclear Power Operations
1820 Water Place
Atlanta, Georgia 30339

NRC Inspector, Browns Ferry

 OFFICIAL COPY

1822
5/11

8205210268 820505
PDR ADOCK 05000296
S PDR

An Equal Opportunity Employer