LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

LICENSEE CODE	LICENSE NUMBER	LICENSE TYPE	CAT
A L J M F 1 (2)	0 0 - 0 0 0 0 0 - 0 0 (3)	4 1 1 1 1 (4)	(5)

REPORT SOURCE: L (6) DOCKET NUMBER: 0 5 0 0 0 3 4 8 (7) EVENT DATE: 0 4 0 8 8 2 (8) REPORT DATE: 0 4 3 0 8 2 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

At 0105 on 4/8/82, while performing FNP-1-STP-43.0 (Spent Fuel Pool Ventilation Radiation Monitors Functional Test), radiation monitor 25A (Fuel Storage Pool Area Gaseous Activity - Ventilation System Isolation) was declared inoperable due to mode selector switch contact problems. Tech. Spec. 3.3.3.1 and Table 3.3.-6 requires a minimum of two radiation monitor channels to be operable for the fuel storage area. Tech. Spec. 3.3.3.1 action statement requirements were met. Health/safety of the public was not affected.

SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP SUBCODE	VALVE SUBCODE
B B (11)	E (12)	X (13)	C K T B R K (14)	E (15)	Z (16)

LER/RO REPORT NUMBER (17)	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 2	—	0 1 5	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
X (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	A (25)	V 1 1 5

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

This event was attributed to dirty contacts on the mode selector switch. The contacts were cleaned and R25A was returned to service at 0230 on 4/8/82.

FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
E (28)	0 9 9 (29)	NA	B (31)	Surveillance Test

ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

NUMBER	TYPE	DESCRIPTION (39)
0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

NUMBER	DESCRIPTION (41)
0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

TYPE	DESCRIPTION
Z (42)	NA

PUBLICITY

ISSUED	DESCRIPTION (45)
N (44)	

8205210309 820430
PDR ADOCK 05000348
S PDR

NRC USE ONLY

NAME OF PREPARER W. G. Hairston, III PHONE: (205) 899-5156