

Mailing Address

Alabama Power Company
600 North 18th Street
Post Office Box 2641
Birmingham, Alabama 35291
Telephone 205 783-6081

F. L. Clayton, Jr.
Senior Vice President
Flintridge Building



Alabama Power

the southern electric system

May 13, 1982

Docket No. 50-348

Director, Office of Management
Information and Program Control
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Sir:

RE: Joseph M. Farley Nuclear Plant
Unit 1
Monthly Operating Data Report

Attached are two (2) copies of the April, 1982 Monthly Operating Report for Joseph M. Farley Nuclear Plant, Unit 1, required by Section 6.9.1.6 of the Unit 1 Technical Specifications. As requested by letter from Mr. John F. Stolz to Mr. Alan R. Barton, dated October 21, 1977, a "Narrative Summary of Operating Experience" is included in the attached report.

If you have any questions, please advise.

Yours very truly,

F. L. Clayton, Jr.
F. L. Clayton, Jr.

FLCJr/KWM:nac

Enclosures

xc: Mr. Ted Cintula (1 copy)
Director, IE (10 copies)
Director, RII (1 copy)

IE24
1/1

JOSEPH M. FARLEY NUCLEAR PLANT
UNIT 1
NARRATIVE SUMMARY OF OPERATIONS
APRIL, 1982

There were two (2) automatic shutdowns in the month of April.

The following safety-related maintenance was performed in the month of April:

1. Performed miscellaneous maintenance on diesel generators.
2. Replaced packing on #5 and #10 river water pumps.
3. Installed new pump assembly on 1A Service Water Pump.
4. Unclogged Boron Injection Tank recirculation pump discharge drain lines.
5. Replaced and rewired river water B train strainer auto blowdown valve.