



Carolina Power & Light Company

MAY 19 1982

Office of Nuclear Reactor Regulation
ATTN: Mr. D. B. Vassallo, Chief
Operating Reactors Branch No. 2
United States Nuclear Regulatory Commission
Washington, D.C. 20555

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 AND 50-324
LICENSE NOS. DPR-71 AND DPR-62
GENERIC LETTER 82-03

Dear Mr. Vassallo:

Carolina Power & Light Company (CP&L) has received Mr. D. G. Eisenhower's Generic Letter 82-03, dated March 31, 1982, in reference to the Brunswick Steam Electric Plant (BSEP) Unit Nos. 1 and 2.

CP&L does not require the application of the approved, but unapplied General Electric ECCS evaluation model changes to offset MAPLHGR penalties due to high burnup fission gas release at Brunswick. The BSEP MAPLHGR values indicate low peak cladding temperatures for each fuel type and subsequent burnup.

Therefore, at this time, CP&L does not wish to apply the GE proposal to the Brunswick Plant.

Yours very truly,

P. W. Howe
Vice President
Technical Services

MSG/lr (n-60)

cc: Mr. J. P. O'Reilly
Mr. J. Van Vliet

8205240293 820519
PDR ADOCK 05000324
P PDR

A001
5.10