

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

SHIELDS L. DALTROFF
VICE PRESIDENT
ELECTRIC PRODUCTION

(215) 841-5001

May 20, 1982

Docket Nos. 50-277
50-278

Mr. J. F. Stolz, Chief
Operating Reactor Branch #4
Division of Licensing
US Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Stolz:

By letters dated December 16, 1980 (S. L. Daltroff to D. G. Eisenhut), April 8, 1981 (J. W. Gallagher to R. W. Reid), August 20, 1981 (S. L. Daltroff to D. G. Eisenhut) and October 14, 1981 (S. L. Daltroff to J. F. Stolz), Philadelphia Electric Company, in response to IE Bulletin 80-17 and its supplements, provided a description of the modification to the scram discharge piping and a schedule reflecting our anticipated completion dates. The purpose of this letter is to provide an update on our schedule and information regarding this modification.

Unit 2 - All previously identified modifications will be completed during the presently ongoing refueling outage scheduled for completion on June 4, 1982.

Unit 3 - Installation of the significant portions of this modification have been completed. Outstanding work to be completed includes only the vent cross-connect and diverse instrumentation installation. As previously identified in our letter of August 20, 1981, the cross connect piping work will be done during the first outage of sufficient duration which requires a full block of the control rod drive system but in no case any later than the next refueling outage, currently scheduled for Spring, 1983. Our October 14, 1981 letter concerning

Aoo'
1/0


Mr. J. F. Stolz, Chief

Page 2

diverse instrumentation indicated that we anticipated completion no later than December 31, 1983, however, we now believe that we will be able to complete this work during the Spring, 1983 refueling outage.

We hope you will find this information useful. Should there be any further questions, please contact us.

Very truly yours,

A handwritten signature in cursive script, appearing to read "J. F. Stolz", written in dark ink.

cc: R. C. Haynes - NRC
C. J. Cowgill - Site Inspector