

50.55(e) Report

ARIZONA



PUBLIC SERVICE COMPANY

P. O. BOX 21666 · PHOENIX, ARIZONA 85036

May 7, 1982

ANPP-20913-GHD/BSK

U. S. Nuclear Regulatory Commission
Region V
Creskide Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, California 94596-5368

rec'd NRC
MAY 13 1982

Attention: Mr. T. W. Bishop, Chief
Reactor Construction Projects Branch

Subject: Time Extension for Revised Report - DER 81-22
A 50.55(e) Potentially Reportable Deficiency Relating
to Premature Time-Out Condition with Agastat Pneumatic
Timing Relays
File: 82-019-026
D.4.33.2

Reference: (A) ANPP-19231, dated October 21, 1981 (Final Report)
(B) Telephone Conversation between J. Eckhardt and
G. Duckworth on February 11, 1982
(C) NRC IE Information Notice No. 82-04, dated March 10,
1982
(D) ANPP-20408, dated March 12, 1982 (Time Extension)

Dear Sir:

The NRC was notified in Reference (B) that the Final Report submitted by Reference (A) will be revised due to discovery of additional Agastat relays in systems other than the Diesel Generator control panels as originally reported. NRC IE Information Notice No. 82-04, Reference (C), and related supplier notification(s) provided information on new lot(s) of relays requiring replacement.

In Reference (D), it was estimated that the Revised Report would be available by May 11, 1982. Due to extensive investigation and evaluation required, it is now expected that this information will be finalized by August 11, 1982 when a complete report will be submitted.

Very truly yours,

E. E. Van Brunt, Jr.
APS Vice President
Nuclear Projects
ANPP Project Director

8205250136 820507
PDR ADOCK 05000528
S PDR

EEVBJr/GHD:skc

cc: See Attached Page 2

IE 27510
82-122

U. S. Nuclear Regulatory Commission
Attention: Mr. T. W. Bishop, Chief
ANPP-20913-GHD/BSK
May 7, 1982
Page 2

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

J. A. Roedel
D. B. Fasnacht
G. C. Andognini
A. C. Rogers
B. S. Kaplan
W. E. Ide
J. Vorees
J. A. Brand
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
R. M. Grant
D. R. Hawkinson
L. E. Vorderbrueggen
G. A. Fiorelli
W. F. Quinn
R. L. Greenfield
Assistant Attorney General
Bataan Memorial Building
Santa Fe, New Mexico 87503

Ms. Patricia Lee Hourihan
6413 South 26th Street
Phoenix, Arizona 85040