

mm  
ARIZONA



PUBLIC SERVICE COMPANY

P. O. BOX 21666 · PHOENIX, ARIZONA 85036

May 14, 1982  
ANPP-20965-GHD/BSK

U. S. Nuclear Regulatory Commission  
Region V  
Creekside Oaks Office Park  
1450 Maria Lane - Suite 210  
Walnut Creek, California 94596-5368

Attention: Mr. T. W. Bishop, Chief  
Reactor Construction Projects Branch

Subject: Time Extension for Report - DER 82-1  
A 50.55(e) Potentially Reportable Deficiency Relating  
to Ex-Core Neutron Monitors May Give Poor Readings  
Due to Cables Having Greater Length and Attenuation  
Than Design  
File: 82-019-026  
D.4.33.2

50-528

Reference: (A) Telephone Conversation between J. Eckhardt and  
G. Duckworth on February 16, 1982  
(B) ANPP-20462, dated March 18, 1982 (Interim Report)

Dear Sir:

The NRC was notified of a potentially reportable deficiency in Reference (A) and an Interim Report was transmitted by Reference (B). At that time, it was estimated that a Final Report would be available by May 18, 1982.

Due to the extensive investigation and evaluation required, it is now expected that this information will be finalized by August 18, 1982, when a complete report will be submitted.

There is no new information or change to the Interim Report at this time.

Very truly yours,

E. E. Van Brunt, Jr.  
APS Vice President  
Nuclear Projects  
ANPP Project Director

EEVBJr/GHD:skc

cc: See Attached Page 2

8205280 313

S

1E27  
5/10  
82-127

U. S. Nuclear Regulatory Commission  
Attention: Mr. T. W. Bishop, Chief  
ANPP-20965-GHD/BSK  
May 14, 1982  
Page 2

cc: Richard DeYoung, Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

J. A. Roedel  
D. B. Fasnacht  
G. C. Andognini  
A. C. Rogers  
B. S. Kaplan  
W. E. Ide  
J. Vorees  
J. A. Brand  
A. C. Gehr  
W. J. Stubblefield  
W. G. Bingham  
R. L. Patterson  
R. W. Welcher  
R. M. Grant  
D. R. Hawkinson  
L. E. Vorderbrueggen  
G. A. Fiorelli

Lynne Bernabei, Esq.  
Harmon & Weiss  
1725 "I" Street, NW  
Suite 506  
Washington, D. C. 20006

R. L. Greenfield  
Assistant Attorney General  
Bataan Memorial Building  
Santa Fe, New Mexico 87503