



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

MAR 29 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

March 23, 1982

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N.W.
Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
File 0260/15525/15526
IE Inspection Report of
October 19-30, 1981
AECM-82/106

Reference: MAEC-81/258, 12/02/81
AECM-82/16, 1/8/82

This letter provides our supplemental response to NRC Violation 416/81-46-02 as transmitted by your letter MAEC-81/258 dated December 2, 1981. Our first response stated that full compliance would be established by January 15, 1982; however, as per our conversation on March 8, 1982, an extension was granted by Mr. R. Butcher until March 24, 1982. Since this time additional corrective actions have been taken to establish and remain in compliance as outlined below:

- a) All temporary changes which exceed the present thirty-days procedural criteria will be incorporated into a revision of the respective procedure or cancelled on or before March 29, 1982.

NOTE: The original violation addressed the failure to incorporate TCN's within six months, but our procedure 01-S-02-2 was revised on 2/16/82 to reduce that time period to 30 days.

- b) Prior authorization will be required from the Plant Manager, Assistant Plant Manager or Nuclear Support Manager prior to initiating a temporary change. This interim measure will be assessed by management and deleted once the initial dependence on temporary changes by the Plant Operations Staff is reduced and procedure changes are accomplished by the normal revision cycle.


8205280 403
Q

Mr. J. P. O'Reilly
NRC

AECM-82/106
Page 2

- c) MP&L will be in full compliance with these additional corrective actions by March 29, 1982.

Yours truly,



J. P. McGaughy, Jr.

ACP:dr

cc: Mr. N. L. Stampley
Mr. R. B. McGehee
Mr. T. B. Conner

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. G. B. Taylor
South Miss. Electric Power Association
P. O. Box 1589
Hattiesburg, MS 39401