

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-5001

SHIELDS L. DALTROFF  
VICE PRESIDENT  
ELECTRIC PRODUCTION

May 19, 1982

Docket Nos. 50-277  
50-278

IE Bulletin 80-25

Mr. R. C. Haynes, Administrator  
US Nuclear Regulatory Commission  
Region I  
631 Park Avenue  
King of Prussia, PA 19046


Dear Mr. Haynes:

This letter provides supplemental information to our letter of March 18, 1981, (S. L. Daltroff, PECO to B. H. Grier, USNRC) regarding IE Bulletin 80-25 concerning overpressurization of safety/relief valve pneumatic supply system. Modifications are being undertaken which will provide a back-up pneumatic supply utilizing compressed gas cylinders. Appropriate overpressure relief devices are being installed in this back-up system. In addition, a high pressure alarm sensor will be installed as part of these modifications. This alarm sensor will be located exterior to containment, between the compressed gas cylinders and the balance of the system, and annunciate, as a general alarm, in the control room. Appropriate direction to operating personnel will be instituted upon completion of this modification so that high pressure will receive proper attention.

This modification has been discussed with our NRC Resident Inspectors.

If there are any further questions, do not hesitate to contact us.

Very truly yours,



cc: C. J. Cowgill

8206010561 Q

IE 11/5/82