



Omaha Public Power District

1623 HARNEY ■ OMAHA, NEBRASKA 68102 ■ TELEPHONE 536-4000 AREA CODE 402

May 25, 1982
LIC-82-206

Mr. Robert A. Clark, Chief
U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Division of Licensing
Operating Reactors Branch No. 3
Washington, D.C. 20555

Reference: Docket No. 50-285

Dear Mr. Clark:

10 CFR 50, Appendix R Requirements

The Commission's letter to Omaha Public Power District, dated April 8, 1982, forwarded the Safety Evaluation Report (SER) on the Fort Calhoun Station alternate safe shutdown capability. The SER provided the results of the Commission's evaluation of the Fort Calhoun Station's alternate safe shutdown capability against the criteria of 10 CFR 50, Appendix R, Section III.G.3. The SER identified three open items. The District's response and/or plans for resolving the three open items is attached.


The April 8, 1982 letter indicated the Commission has a special concern about the effects of associated circuits on alternate shutdown capability (open item three). This special concern was denoted by your statement: "if your response to open item three is not complete . . . , you will be found in violation of 10 CFR 50.48." The District had previously addressed this concern in our letter dated March 27, 1981 and had considered our response to be complete. Therefore, to ensure there is a common understanding on what is considered a "complete response" on this issue, the District initiated a telephone conference (telecon) with the Commission's technical reviewers. The telecon held on April 20, 1982 included Messrs. Patterson and Gamble of the District; Messrs. Tourigny, Ridgely, Lobel, Wambach, and Ravante of the Commission; and Messrs. MacDougall and Smith of Brookhaven National Labs. The District's initial response to this issue was provided in our letter of March 27, 1981 (i.e., our response to recommendation 1.3)) was collectively reviewed during this telecon. A consensus was reached that, had the

*Adock
5/1/1*

Mr. Robert A. Clark
LIC-82-206
Page Two

District included the control room circuits in our March 27, 1981 response, it would have been considered a "complete response." The control room circuits were considered associated circuits in our initial review, although they were not specifically identified as such in our March 27, 1981 letter. Our attached response to open item three has been revised to include the control room and this should resolve the Commission's concerns.

Sincerely,



W. C. Jones
Division Manager
Production Operations

Attachment

cc: LeBoeuf, Lamb, Leiby & MacRae
1333 New Hampshire Avenue, N.W.
Washington, D.C. 20036

Attachment

OMAHA PUBLIC POWER DISTRICT'S RESPONSE TO THREE OPEN ITEMS IDENTIFIED IN THE COMMISSION'S LETTER DATED APRIL 8, 1982

Open Item 1

Modification must be made to the plant such that no wiring changes or pulling of fuses is necessary to achieve and maintain hot standby.

Response

This comment relates to the pressurizer heaters. A control switch will be installed at the motor control center or at the alternate shutdown (ASD) panel to allow local control of one bank of pressurizer heaters. Also, necessary wiring changes will be made to provide means for isolation of heater control circuits from the fire area (cable spreading room and control room), and to ensure proper operation following fire in the cable spreading room and/or control room. These modifications will be completed during the next Fort Calhoun Station refueling outage tentatively scheduled to start in December 1982.

Open Item 2

A source range flux monitor independent of the cable spreading room and control room should be installed on the new instrument rack (ASD panel).

Response

The existing source range flux monitors for the Fort Calhoun Station are scheduled to be replaced during the 1984 refueling outage. At that time, a remote source range flux monitor, independent of the reactor pressure system drawers in the control room and cable spreading room, will be installed at the ASD panel. Please note that because of the long equipment delivery times on this equipment an earlier replacement is not feasible.

Open Item 3

The licensee should address the concern that there could be non-safety related circuits that are associated with the alternate safe shutdown circuits that could fail due to a fire and affect safe shutdown by short circuits or grounds.

Response

As explained in our response dated March 27, 1981 and clarified in our telephone conversation of April 20, 1982, the alternate shutdown capability has been provided for achieving hot shutdown in case of fire in the cable spreading room and/or control room. Effects of fire induced failures in the associated circuits (including non-safety related circuits that are associated with alternate safe shutdown circuits) were evaluated and it was decided to consider all cables in the cable spreading room and/or control room as associated circuits. Also, it was

decided to identify and isolate cables required for achieving hot shutdown from these associated circuits. Tables B, C, and D included in our March 27, 1981 letter provide a listing of cables required for hot shutdown and discuss various isolation schemes. These isolation schemes have been reviewed and accepted by the NRC. Also, necessary modifications as detailed in our previous submittals have been installed to ensure that fire induced failures in any circuits located in the cable spreading room and control room (including non-safety related circuits) will not prevent proper operation of equipment required for achieving safe shutdown. As per the telephone conversation of April 20, 1982 between NRC and District representatives, the District's submittal of March 27, 1981, as supplemented by this response, is considered a complete response and no additional action is required on this item.