



PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4500

V. S. BOYER
SR. VICE PRESIDENT
NUCLEAR POWER

May 6, 1982

Docket Nos. 50-277
50-278

Mr. R. C. Haynes, Administrator
Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Dear Mr. Haynes:

This letter is in response to your letter to Philadelphia Electric Company dated December 24, 1981 and provides a status report for those activities scheduled for completion by March 15, 1982.

ITEM 7

Perform an analysis of the stack sampling system to verify that samples are representative, and if they are not, provide a description of necessary remedial actions and a schedule for their completion.

This will be accomplished by no later than March 15, 1982.

RESPONSE

An analysis of the stack sampling system was performed as specified. The results of the analysis indicate that the stack sampling system should be adequately representative when functioning as designed.

Reports of the analysis are available for your inspection.

The scope of the analysis was extended voluntarily to include the roof vent sample system. The investigation revealed evidence of occasional moisture in the filters and icing in the sample lines.

Corrective action shall be to heat trace the sample lines and to make minor piping modifications. These changes shall be implemented by November 1, 1982. It is expected that this action will resolve the condensation and icing problems.

ITEM 3C


Complete initial training of other personnel. Training of other personnel will be accomplished no later than April 15, 1982.

RESPONSE

Training of emergency response personnel has been conducted throughout the months of January, February, March and April. By April 15, formal classroom training had been conducted for approximately 400 plant and corporate personnel.

In coordination with this training, repetitive drills have been conducted for specific groups of personnel and combinations of related groups to develop proficiency in performance of their prescribed functions.

Very truly yours,

A handwritten signature in cursive script, appearing to read "V. S. Boyer". The signature is written in dark ink and is positioned below the typed name "Very truly yours,".