

THE CINCINNATI GAS & ELECTRIC COMPANY



E. A. BORGMANN  
SENIOR VICE PRESIDENT

May 25, 1982  
QA-1778

U.S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Attention: Mr. J. G. Keppler  
Regional Administrator

RE: WM. H. ZIMMER NUCLEAR POWER STATION UNIT I  
10CFR50.55(e) - ITEM S-2 - LAMINATION IN  
3x3x $\frac{1}{2}$  ANGLE IRON - DOCKET NO. 50-358,  
CONSTRUCTION PERMIT NO. CPPR-88, W.O. #57300,  
JOB E-5590, FILE NO. NRC-9, S-2

Gentlemen:

This letter constitutes an interim report concerning the subject condition initially reported under the requirements of 10CFR21. Further review has determined this item is applicable to the Zimmer site under 10CFR50.55(e).

As stated in our previous report, QA-1703, dated April 15, 1982, an accounting was performed to locate all 3x3x $\frac{1}{2}$  A-36 angle iron, manufactured by Northwestern Steel and Wire Company of heat #66221. This investigation was prompted by the discovery of a lamination, approximately 1/8" in depth and 1/32" wide at the Zimmer site. Further review of the purchase order found that only 240' of the material was actually received. At this time, all material has been located and is under the control of several nonconformance reports. H. J. Kaiser Co., the principal constructor, has notified all steel suppliers that material manufactured by the aforementioned vendor will no longer be accepted at the Zimmer site.

A final report will be submitted by July 31, 1982, after disposition of the applicable nonconformance reports.

8206070498 820525  
PDR ADOCK 05000358  
S PDR

JUN 1 1982  
IF 27 5/10


Mr. J. G. Keppler  
Regional Administrator  
May 25, 1982, QA-1778  
Page 2

We trust the above will be found acceptable as an interim report under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By



E. A. BORGMANN  
SENIOR VICE PRESIDENT

FKP:ec

cc: NRC Resident Inspector  
Attn: W. F. Christianson  
NRC Office of Inspection and Enforcement  
Washington, D.C. 20555