



Carolina Power & Light Company

JUN 7 1982

Office of Nuclear Reactor Regulation
ATTN: Mr. D. B. Vassallo, Chief
Operating Reactors Branch No. 2
United States Nuclear Regulatory Commission
Washington, D.C. 20555

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 AND 50-324
LICENSE NOS. DPR-71 AND DPR-62
GENERIC LETTER 82-03 - SUPPLEMENTAL INFORMATION

Dear Mr. Vassallo:


On May 19, 1982, Carolina Power & Light Company (CP&L) responded to Mr. D. G. Eisenhower's Generic Letter 82-03 for the Brunswick Steam Electric Plant, Unit Nos. 1 and 2.

On June 1, 1982, NRC and CP&L held a conference call to discuss our response to Generic Letter 82-03. As a result of this conversation, CP&L is providing the following clarification to our response.

For the Brunswick Plant, CP&L endorses the General Electric (GE) application of the NRC approved, but unapplied, ECCS evaluation model changes to offset Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) penalties as referenced in GE's May 6, 1981 letter to NRC.

Should you have additional questions, please contact our staff.

Yours very truly,


for P. W. Howe
Vice President
Technical Services

MSG/lr (n-77)

cc: Mr. J. P. O'Reilly (NRC-R11)
Mr. J. A. Van Vliet (NRC)

A001

8206100162 820607
PDR ADOCK 05000324
P PDR