


VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

R. H. LEASBURG
VICE PRESIDENT
NUCLEAR OPERATIONS

April 12, 1982



Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. Robert A. Clark, Chief
Operating Reactors Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Serial No. 203
NO/JHL:acm
Docket No. 50-338
License No. NPF-4

Gentlemen:

AMENDMENT TO OPERATING LICENSE NPF-4
NORTH ANNA POWER STATION UNIT NO. 1
PROPOSED TECHNICAL SPECIFICATION CHANGE NO. 60

Pursuant to 10 CFR 50.90, the Virginia Electric and Power Company requests an amendment in the form of changes to the Technical Specifications, to Operating License NPF-4 for the North Anna Power Station, Unit No. 1. The proposed changes are enclosed and have been designated Change No. 60.

This proposed change is to modify Technical Specification 3/4.6.3.1, Table 3.6-1 for North Anna Unit No. 1 to reflect the installation of two additional containment isolation valves. There is one manual isolation valve and one check valve to be added to the list of containment isolation valves in Technical Specification Table 3.6-1. These valves are being added for the Fire Protection Supply Standpipe (Penetration No. 34). The effect of the increased fire protection equipment proposed by this change would be to protect the safety related equipment from fire and reduce the chance of a fire related accident. Addition of the category I containment isolation valves meets the requirements for containment isolation integrity as specified in the FSAR. The installation of these valves satisfies the seismic design criteria for safety related systems. The proposed Technical Specification Change is enclosed in Attachment 1. A discussion of the proposed change is enclosed in Attachment 2.

This request has been reviewed and approved by the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control staff. It has been determined that this request does not involve an unreviewed safety question as defined in 10 CFR 50.59.

We have evaluated this request in accordance with the criteria in 10 CFR 170.22. Since this request involves a safety issue which the staff should be able to determine does not pose a significant hazard consideration for Unit 1, a Class III license amendment fee is required for Unit 1. Accordingly, a voucher check in the amount of \$4000.00 is enclosed in payment of the required fees.

Very truly yours,

R. H. Leasburg

APR 14 1982
/1
w/check!
\$4000.00

8204150455 820412
PDR ADOCK 05000338
PDR

VIRGINIA ELECTRIC AND POWER COMPANY TO Harold R. Denton

Attachments

1. Proposed Technical Specification Change No. 60
2. Discussion of Proposed Technical Specification Change No. 60
3. Voucher Check No. 17077 for \$4000.00

cc: Mr. James P. O'Reilly, Regional Administrator
Office of Inspection and Enforcement
Region II

COMMONWEALTH OF VIRGINIA)
)
CITY OF RICHMOND)

The foregoing document was acknowledged before me, in and for the City and Commonwealth aforesaid, today by R. H. Leasburg, who is Vice President-Nuclear Operations, of the Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 12th day of April, 19 82.

My Commission expires: 2-26, 19 85.

Ann C. Morse
Notary Public

(SEAL)

Attachment 1