

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	3	3	1	7	0	3	0	9	8	2	3	0	4	0	8	8	2	9
60	61	ROCKET NUMBER					68	69	EVENT DATE					74	75	REPORT DATE					80			

0 2 | During normal operation while performing surveillance testing, 4 KV emer
0 3 | gency bus undervoltage relay 127-3 tripped conservatively high at 29.2 v
0 4 | olts. Technical Specification Table 3.2-B requires a trip level setting
0 5 | of 24 +/- 4 volts. The undervoltage relay on the redundant 4 KV emergenc
0 6 | y bus was operating properly. There has been one previous similar occur
0 7 | rence (see RO 76-22).

0	8	9											90									
SYSTEM CODE			CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE							
E	B	11	E	12	A	13	R	E	L	A	Y	X	14	F	15	Z	16					
EVENT YEAR			SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.													
18	2	21	0	2	3	24	0	3	28	L	30	0	32									
ACTION TAKEN			FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPD-4 FORM 308		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER					
E	18	Z	19	Z	20	Z	21	0	0	0	0	N	23	N	24	A	25	G	10	8	10	25
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55

Instrument drift was the cause of the event. Relay 127-3 was promptly re
calibrated and tested satisfactorily. Relay 127-3 is a General Electric
Type HGA relay. No further corrective action is planned.

1	3	
1	4	

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION					
1	5	F	28	0	9	7	29	NA	30	B	31	Surveillance test	32

ACTIVITY CONTENT
RELEASED OF RELEASE

1 5 2 33 2 34 NA

AMOUNT OF ACTIVITY 35

LOCATION OF RELEASE 36

PERSONNEL EXPOSURES									
NUMBER			TYPE		DESCRIPTION				
1	7	0	0	0	37	Z	38	NA	39

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	4	0	0
0	0	0	40
			NA

1		2		3		4		5		6		7		8		9		10		11		12	
LOSS OF OR DAMAGE TO FACILITY (43)																							
TYPE		DESCRIPTION																					
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
		Z	(42)	NA																			

8 9 10
PUBLICITY
ISSUED DESCRIPTION (45) 8204160133 820408
2 0 [N] (44) NA PDR ADOCK 05000331
7 8 9 10 S PDR NRC USE ONLY

NAME OF PREPARER David M. Varner

PHONE 319-851-5611