

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

REPORT SOURCE	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80				
	L	6	0	5	0	-	0	3	2	5	7	0	3	0	4	8	2	8	0	3	3	0	8	2	9

DOCKET NUMBER

EVENT DATE

REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

During plant operation, routine surveillance revealed that reactor pressure indicator 1-C32-PI-3332, located on the remote shutdown panel, showed 1,030 psi while actual pressure was 1,000 psi. The indicator was then declared inoperable in accordance with technical specifications. This event did not affect the health and safety of the public.

Technical Specifications 3.3.5.2, 6.9.1.9b

09		SYSTEM CODE I C		11	CAUSE CODE E		12	CAUSE SUBCODE F		13	COMPONENT CODE I N S T R U						14	COMP. SUBCODE I		15	VALVE SUBCODE Z		16
7	8	9	10		11		12		13						18		19			20			
17		LER-RO REPORT NUMBER		EVENT YEAR 8 2		21	22	SEQUENTIAL REPORT NO. 0 3 4		24	26	OCCURRENCE CODE 0 3		28	29	REPORT TYPE L		30	REVISION NO. 0		32		
ACTION TAKEN C		FUTURE ACTION Z		18	19	EFFECT ON PLANT Z		20	SHUTDOWN METHOD Z		21	HOURS 0 0 0 0		22	ATTACHMENT SUBMITTED N		23	NPRD-4 FORM SUB. Y		24	PRIME COMP. SUPPLIER N		25
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54		

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 A calibration check determination that the indicator was out of tolerance, combined
1 1 with a failed indicator conversion resistor, R5, caused this event. The indicator,
1 2 Model No. 1151, and the conversion resistor were replaced in accordance with the
1 3 manufacturer's recommendations and the indicator was returned to service. As plant
1 4 documentation shows this event is isolated, no further corrective action is planned.

[illegible]

PUBLICITY
 ISSUED DESCRIPTION (45)
 2 0 N (44)
 S
 8204160177 820329
 PDR ADOCK 05000325
 PDR
 NRC USE ONLY
 68 69 70 71 72 73 74 75 76 77 78 79

M. J. Pastva, Jr.

PHONE _____

(919) 457-9521