


Georgia Power Company
Post Office Box 4545
Atlanta, Georgia 30302
Telephone 404 522-6060

Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202
Telephone 205 870-6011



April 5, 1982

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 3100
101 Marietta Street
Atlanta, GA 30303

File: X7BG03-M22
Log: GN-166



Reference: Vogtle Electric Generating Plant - Unit 1 and 2
50-424, 50-425 Leaks in Containment Cooling Coil Units

Attention: Mr. James P. O'Reilly

Gentlemen:

On March 4, 1982 Georgia Power Company reported a potential deficiency to the Commission concerning some defective cooling coils in the containment coolers. Georgia Power Company is conducting an engineering evaluation to determine if the leaks could have prevented these coolers from performing their functional requirements. The engineering evaluation is scheduled for completion in mid-May.

Georgia Power Company expects to submit a final report to the NRC on this matter by June 4, 1982.

This reply contains no proprietary information and may be placed in the NRC Public Document Room.

Yours truly,

D. O. Foster
Project General Manager

CWH/tlp

xc: U. S. Nuclear Regulatory Commission
Attn: Victor J. Stello
Office of Inspection and Enforcement
Washington, D. C. 20555

R. J. Kelly	O. Batum
R. E. Conway	H. H. Gregory, III
G. F. Head	E. D. Groover
J. H. Boykin	L. T. Gucwa
D. E. Dutton	M. Malcom
D. L. McCrary	C. R. Miles, Jr.
R. A. Thomas	M. Manry
J. A. Bailey	R. W. Staffa

J. L. Vota

OFFICIAL COPY

B204160347 B20405
PDR ADDCK 05000424
S PDR