

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261



R. H. LEASBURG
VICE PRESIDENT
NUCLEAR OPERATIONS

April 13, 1982

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. Robert A. Clark, Chief
Operating Reactors Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Serial No. 195A
NO/ERS,Jr.:acm
Docket Nos. 50-338
50-339
License Nos. NPF-4
NPF-7

Gentlemen:


STEAM GENERATOR INSPECTION PORTS
NORTH ANNA UNITS 1 & 2

Since our letter to you on March 30, 1982 (Serial No. 195), we have continued to review this matter and have held several telephone conversations with the NRC staff including Mr. T. H. Novak. On April 5, 1982, we further discussed this subject in a telephone call to Mr. Novak and others. As a result of that discussion, we are continuing to proceed with installation of steam generator inspection ports for North Anna Unit 2 during the current refueling outage. These ports will be located between the fifth and sixth tube support plates. Unit 1 steam generators will be similarly modified during the next scheduled refueling outage.

This new location provides a suitable and an acceptable alternative to the previous location. Inspections of the minimum radius U-bends, seventh support plate, and flow slots can be conducted from this new location. This new location will eliminate the need for weld buildup on the steam generator exterior and will eliminate the need to remove the upper seismic support ring.

We understand that the staff has found the new location of the inspection port technically acceptable.

Very truly yours,


R. H. Leasburg

cc: Mr. R. C. DeYoung, Director
Office of Inspection and Enforcement
Washington, DC 20555

Mr. J. P. O'Reilly, Regional Administrator
Region II, U. S. NRC
Atlanta, GA 30303

Mr. D. G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation
Washington, DC 20555

A001
1/0