

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	Y	I	P	S	3	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT 58	

CON'T

0 1 7 8 REPORT SOURCE L 6 0 5 0 0 0 2 8 6 7 0 3 2 7 8 2 8 0 4 0 9 8 2 9 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While at cold shutdown during a refueling outage, a small leak on the
0 3 | shell side of steam generator no. 32 was observed. An oval-shaped hole
0 4 | was discovered in the upper girth weld of the generator. The hole
0 5 | measures approximately 5/8 inch by 1/8 inch. As the steam generator
0 6 | shell is considered to be an extension of the primary containment
0 7 | boundary, this event is reportable under Technical Specification
0 8 | 6.9.1.7.C.

0	9	SYSTEM CODE		C	B	11	CAUSE CODE		E	12	CAUSE SUBCODE		B	13	COMPONENT CODE				H	T	E	X	C	H	14	COMP. SUBCODE		F	15	VALVE SUBCODE		Z	16							
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47
LER-RO REPORT NUMBER		EVENT YEAR		SEQUENCE REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.		ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER												
17		21		24		28		30		32		33		34		35		36		37		41		42		43		44												
8		2		0		1		T		0		X		X		Z		Z		0		N		Y		N		W												
18		19		20		21		22		23		24		25		26		27		28		29		30		31		32												

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 As the leak was on the secondary side of the generator, secondary water
1 1 level was lowered to a point below that of the hole, thereby terminating
1 2 the leakage. Further analysis of this event and repair of the steam
1 3 generator shell will be performed during the present refueling outage. No
1 4 similar events have been reported to date.

7		8		9		FACILITY STATUS		% POWER		OTHER STATUS		(30)		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION		(32)			
1	5	H		(28)		0	0	0	(29)	NA			B		(31)	VC Inspection					
7		8		9		10		11		12		13		44		45		46		8	

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 2 33 34 NA

AMOUNT OF ACTIVITY (35)

LOCATION OF RELEASE (36)

NA

PERSONNEL EXPOSURES										
NUMBER			TYPE	DESCRIPTION						
1	7	0	0	0	(37)	Z	(38)	NA		

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	8	0	0
0	0	0	40
		NA	

8 9		11 12		
TYPE		DESCRIPTION		(43)
1	9	Z	(42) NA	

7 8 9 10
PUBLICITY
ISSUED DESCRIPTION (45)
[2][0] [Y] (44) Press release issued by PASNY. NRC USE ONLY

PHONE: 914-739-8200, X217