

CONTROL BLOCK: 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

REPORT SOURCE: L 6 0 5 0 0 0 3 4 8 7 0 3 0 5 8 2 8 0 4 0 2 8 2 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 | At 1245 on 3/05/82 the remote shutdown panel pressurizer level indicator LI-459Z was

0 3 | declared inoperable when it failed high. Tech. Spec. 3.3.3.5, in part, requires the

0 4 | LI-459Z instrumentation channel to be operable. Tech. Spec. 3.3.3.5 action statement

0 5 | requirements were met. Health/safety of the public was not affected.

0 6 |

0 7 |

0 8 |

0 9 |

SYSTEM CODE: I C 11

CAUSE CODE: E 12

CAUSE SUBCODE: G 13

COMPONENT CODE: I N S T R U 14

COMP. SUBCODE: T 15

VALVE SUBCODE: Z 16

EVENT YEAR: 8 2

SEQUENTIAL REPORT NO.: 0 0 7

OCCURRENCE CODE: 0 3

REPORT TYPE: L

REVISION NO.: 0

LER NO. REPORT NUMBER: 17

ACTION TAKEN: A 18

FUTURE ACTION: Z 19

EFFECT ON PLANT: Z 20

SHUTDOWN METHOD: Z 21

HOURS: 0 0 0 0

ATTACHMENT SUBMITTED: N 23

NPRO-4 FORM SUB.: N 24

PRIME COMP. SUPPLIER: N 25

COMPONENT MANUFACTURER: B 0 8 0 0 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 | This event was caused by a faulty transmitter amplifier board. The board was replaced

1 1 | and following the transmitter calibration, LI-459Z instrumentation channel was

1 2 | returned to service at 1600 on 3/10/82.

1 3 |

1 4 |

1 5 | E 28 0 0 0 29 NA 30 METHOD OF DISCOVERY: B 31 Routine Inspection 32

1 6 | Z 33 Z 34 NA 35 LOCATION OF RELEASE: NA 36

1 7 | 0 0 0 37 Z 38 NA 39

1 8 | 0 0 0 40 NA 41

1 9 | Z 42 NA 43

2 0 | N 44 NA 45

NRC USE ONLY

8204160408 820402
PDR ADOCK 05000348
S PDR

irston, III

PHONE (205) 899-5156